

Government of Bihar
Public Health Division Supaul
Water Quality Testing Report

Received Sample on date : 16.07.2025

District- Supaul				Testing date - 16.07.2025												
SL. No.	Block	Location of Source	Type of Source	Sample Collected by : School Staff												
				Parameters tested												
				pH	Turbidity	Total hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Sulphate	Fluoride	Arsenic	Total Coll.
1	Supaul	St. Xavier's High School, Kharaiel, Brahm Stnan Chowk, Supaul	Boring water	-	1	264	72.8	20	30	304	0.18	3.20	8	0.74	-	< 1.1
Desirable Unit				6.5 - 8.5	1	200	75	30	250	200	0.3 mg/l	45 mg/l	200	1.00	0.01 mg/l	-
Maximum Permissible limit in absence of alternate source				NR	5 NTU	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	1 mg/l	NR	400 mg/l	1.5 mg/l	NR	-


Memo No. - 086 Supaul, Dated - 16-07-2025

Copy to Principal St. Xavier's High School, Kharaiel, Supaul to inform regarding refernce to his letter No. - SXHS/PHED/01/25

Dated :- 16/07/2025


Lab Assistant


Chemist


Assistant Engineer
P.H. Division, Supaul

**ASSISTANT ENGINEER
PH DIVISION, SUPAUL**